

The following questions have been asked, the responses are in Red.

A walk through has been scheduled for Wednesday May 1, 2019 at 2 pm. You will meet with TJ at the Union booster station it is directly across from 281 E Union Heights Dr, Union, Wa. 98592. Then after the walk through at the Union booster station you will follow TJ out to the Viewcrest Beach well house.

The propane companies want the first filling when they do the work. Are the propane tanks to be filled?

Yes

Please confirm that the Union slab is existing and the Viewcrest will require one? Union has existing slab that propane tank will sit on; Viewcrest Beach will need a concrete slab for propane tank

Will you require a factory-trained startup and time for a utility representative training? No

Do you have minimum generator size in KW? No

Will you require county inspections for the propane work? Yes

Will the 3-phase generator be 120-208 volt? 277/480 volt

Is there any specs? No