



ADDENDUM 1

Project: Generator Installation – Canal Mutual and Lakewood Heights

Date: 03/20/2024

To: Prospective Bidder

From: Mason County PUD 1

Cc: TJ Goos, MCPUD 1

ADDENDUM

Bidder shall sign and attach a copy of this Addendum with Bid Proposal.

Changes and clarifications to the Bid Documents and Plan-Set for the above-referenced project are as follows:

1. Working hours? Monday through Friday 8:00 a.m. to 4:30 p.m.
2. Can the manual transfer switch at Canal Mutual be removed? Yes.
3. Is a concrete slab required under the liquid propane tank? No.
4. Is a concrete slab required under the generators? Yes, per the scope of work.
5. Do propane tanks need to be filled? Yes, per the scope of work.
6. Is it okay to surface mount conduit? Yes.
7. What is the max amount of time power can be off at each location? Preferably no longer than 4 hours and will need 24 hours' notice before outage.
8. Can the transfer switch be mounted on the outside of the building? No, needs to be inside.

Acknowledgement of receipt of Addendum: _____

SIGNATURE OF BIDDER