



## ADDENDUM 1

---

Project: Generator Installation – Holiday Beach and Island Hide-A-Way

Date: 05/08/2026

To: Prospective Bidder

From: Mason County PUD 1

Cc: Brandy Milroy & TJ Goos, MCPUD 1

### ADDENDUM

**Bidder shall sign and attach a copy of this Addendum with Bid Proposal.**

Changes and clarifications to the Bid Documents for the above-referenced project are as follows:

#### Both sites

1. Does the transfer switch need to be inside? Yes, per RFP under scope of work.
2. Does the contractor have to get permits or the PUD? The Contractor is responsible for permits.
3. Will the PUD clear and brush the sites? Yes, the sites will be prepared and level for the equipment.
4. If Kohler does not manufacture specific 40KW & 24KW what sizes should be used? Holiday Beach generator size can be sized up to a 48KW liquid cooled and Island Hide-A-Way generator size can be sized up to 38KW liquid cooled.
5. Both meters at both sites are not bypass meters, being we will be intercepting the feeder wire in the meter and rerouting to the ATS will the PUD require these meters to be upgraded to Bypass meter bases?  
No.
6. Is there a standard bid form? No, provide specs for equipment and total price for all services at each location, including applicable sales tax and prevailing wage.

#### Holiday Beach

7. Does the trail have to be kept clear? Yes, the trail is our water line that goes up to the reservoir. Nothing should be located on the trail.

#### Island Hide-A-Way

8. The exiting panel doesn't have enough space for the new circuits, should the panel be replaced? There is now space available for additional breaker, the panel doesn't need to be upgraded at this time.

Acknowledgement of receipt of Addendum: \_\_\_\_\_

SIGNATURE OF BIDDER