

View Ridge Heights Water System ID #918450													
Location Information		System-Owned Portion				Customer-Owned Portion			Entire Service Line Material Classification (required)	Other Potential Sources of Lead		Lead Service Line Replacement (LSLR)	
Location Identifier (required)		System-Owned Portion Service Line Material Classification (required)	If Non-Lead in Column D, Was Material Ever Previously Lead?	Basis of Material Classification (required)	Notes	Customer-Owned Portion Service Line Material Classification (required)	Basis of Material Classification (required)	Notes		Is there a Lead Connector?	Is there Lead Solder in the Service Line?	Date of System-owned LSLR	Date of Customer-owned LSLR
Street Address	Other Location Identifier												
Water systems must track addresses of all service lines in their internal inventory. If the system does not use addresses for their location identifier, other options could include a unique ID, parcel number, landmark, intersection, block, or other details to specify service line locations.		Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field	Dropdown list. Select Yes, No, or Don't know. Important for determining if downstream/ customer-owned galvanized service line requires replacement	Select option from drop down list. If "Other," describe in the Notes field	Use this field for documenting additional relevant information.	Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.	Select option from drop down list.	Use this field for documenting additional relevant information.	Select the proper classification using dropdown list and "Classifying SLs" tab.	For example, lead gooseneck or pigtail where the water main is connected to the service line	Select Yes, No, or Don't Know		
71 NE RAINBOW PL S		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
121 NE RAINBOW PL N		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
31 NE BOAD HAVEN RD		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
3821 NE NORTH SHORE RD		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
71 NE VIEW CT		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
130 NE RAINBOW PL N		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
80 NE VIEW RIDGE DR		Non-Lead plastic	No	Field inspection		Non-Lead galvanized	Field inspection		Galvanized Requiring Replacement	No	No		
71 NE BOAD HAVEN RD		Non-Lead plastic	No	Field inspection		Non-Lead galvanized	Field inspection		Galvanized Requiring Replacement	No	No		
101 NE RAINBOW PL S		Non-Lead plastic	No	Field inspection		Non-Lead galvanized	Field inspection		Galvanized Requiring Replacement	No	No		
40 NE FIR LN		Non-Lead plastic	No	Field inspection		Non-Lead copper	Field inspection		Non-Lead	No	No		
611 NE BECK RD		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
141 NE VIEW CT		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
3843 NE NORTH SHORE RD		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
51 NE VIEW RIDGE DR W		Non-Lead plastic	No	Installation date after lead ban		Non-Lead plastic	Build/installation date after lead ban		Non-Lead	No	No		
70 NE DULALIP LANDING		Non-Lead plastic	No	Installation date after lead ban		Non-Lead plastic	Field inspection		Non-Lead	No	No		
80 NE FIR LN		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
135 NE BOAD HAVEN RD		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
31 NE RAINBOW PL S		Non-Lead plastic	No	Field inspection		Non-Lead galvanized	Field inspection		Galvanized Requiring Replacement	No	No		
141 NE RAINIER PL N		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
131 NE VIEW RIDGE DR		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
131 NE RAINBOW PL N		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
81 NE VIEW RIDGE DR W		Non-Lead plastic	No	Field inspection		Non-Lead plastic	Field inspection		Non-Lead	No	No		
91 NE RAINIER PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
40 NE RAINIER PL S		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
61 NE RAINBOW PL S		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
21 NE VIEW RIDGE DR W		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
90 NE RAINIER PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
10 NE RAINBOW PL NORTH		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
150 NE RAINIER PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
81 NE RAINBOW PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
60 NE BOAD HAVEN RD		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
110 VIEW CT		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
100 NE RAINBOW PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
3801 NE NORTH SHORE RD		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
60 NE VIEW RIDGE DR W		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
151 NE VIEW CT		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
30 NE RAINIER PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
50 NE VIEW CT/20 NE DUNCANS RD		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
20 NE RAINIER PL S		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
20 NE FIR LN		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
111 NE VIEW RIDGE DR		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
111 NE RAINIER PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
60 NE VIEW CT		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
70 NE VIEW RIDGE DR W		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
90 NE RAINBOW PL N		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
111 NE BOAD HAVEN RD		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		
96 NE BOAD HAVEN RD		Unknown- unlikely lead	Don't know	Other		Unknown- unlikely lead	Statistical method		Unknown	Don't Know	Don't Know		

[illegible]