



ADDENDUM 1

Project: Eldon to Duckabush Reconductor Project

Date: 10/06/2026

To: Prospective Bidders

From: Jeremiah Waugh, PE, Engineering Manager, Project Manager for PUD1

Cc: Kristin Masteller, PUD1; Emily Novotny, PE, Project Engineer for Toth

ADDENDUM

Bidder shall sign and attach a copy of this Addendum with Bid Proposal.

Changes and clarifications to the Bid Documents and Plan-Set for the above-referenced project are as follows:

1. If you are not already pre-qualified, you'll need to complete and send me the pre-qualification application by 3:30 p.m. on October 16, 2026, before you can bid.
2. Federal Funding / Prevailing Wage – This is a FEMA funded project. Review the appendices of the bid binder for more information.
3. Our annual tree trimming has started in the area, so minimal tree trimming, but plan on 15 ft radial trimming for taller poles as everything else will be trimmed to the ground.
4. The overhead can be fed from either side which will help minimize outages.
 - a. Schedule outages well in advance with PUD1
5. Substantial Completion of Project (May 2027. Work must be done in consecutive weeks-no de-mob/re-mob)
6. Clarification
 - a. Starting at the southmost end EX-20521 / EDR-184 and working north.
7. Communication Attachments
 - a. HCC - Cost to transfer - Adder - EX-20521 / EDR-184 to EDR-144
 - i. Supply Material - (Will send out cut sheets next week)
 - b. PUD – Cost to transfer – Adder EDR-144 to EDR-63 Adder
 - i. Supply Material - (Will send out cut sheets next week)
 - c. Lumen – Cost to remove — Adder
8. Changes – Reflected in For Construction Plans
 - a. Switch to move from EDR-123 to EDR-122
 - b. EDR-172 – No GOAB/GOS replacement—Existing is 50-2
 - i. Framing only Required
 - c. EDR-180 TAP → Ht-CI will be updated
 - d. EDR-147 Existing grid # 20621
 - e. Adders for upsizing taps
 - i. 3437 – EX.3437 Tap of EDR-84
 - ii. 5151—EX.5151 Tap of EDR-101
 - iii. 3558—EX. 3558 Tap of EDR-122
9. Lay down yard - Access to PUD1 Yard 6am to 4:30pm (Monday – Thursday)

- a. Good condition poles. These should be returned to PUD1 yard so that we can reuse them. Anything in good working order back to the shop
 - b. Anything not reusable can go in scrap piles
- 10. Questions/emails: Emily enovotny@tothassociates.com & Jeremiah jeremiahw@mason-pud1.org; CC Kristin kristinm@mason-pud1.org
- 11. The meeting minutes and any questions that come up following the walk-thru will be answered in Addendum 1.
- 12. I will send out Addendum 1 on Wednesday evening or Thursday morning answering any questions that come up.
- 13. Cutoff for addenda q's will be Friday October 16th at 3:30pm
 - a. I will send the final addendum, if any, before the end of day Monday October 19th
 - b. All addenda must be signed and included with the bid
 - c. Bid Tabulation – A new bid sheet will be sent with addendum 2
 - i. To include Communication, taps, etc.
- 14. Bidding -> Estimate is \$1,250,000 1 million six-hundred and twenty-five thousand
 - a. Mobilization not to exceed 10% of construction total
- 15. Please carpool and be safe as the project is along the highway and can get busy
- 16. Additional Questions/Clarifications
 - a. **PUD will ribbon all poles to be returned to PUD**
 - b. **PUD will serve as laydown yard**
 - c. **Contractor responsible for offloading shipped materials (supply forklift)**
 - d. **Contractor to provide dumpster**
 - e. **Contractor to supply all material except any required replacement transformers**
 - f. **Contractor to transfer all line equipment per drawings**
 - g. **Contractor to install new anchors**
 - h. **Switching/Holds must be scheduled for M-Th (7am to 3pm)**
 - i. **NO HOLDS ON FRIDAYS**
 - i. **Tree Trimming only expected on taller and new pole installations.**

Acknowledgement of receipt of Addendum: _____

SIGNATURE OF BIDDER